

ANNUAL WATER QUALITY REPORT

Reporting Year 2025



Presented By



CSD

Denair Community
Services District

Our Commitment

We are pleased to present to you this year's annual water quality report. This report is a snapshot of last year's water quality covering all testing performed between January 1 and December 31, 2025. Included are details about your source of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies.

Where Does My Water Come From?

The water sources in use for Denair Community Services District are four deep groundwater wells, Public Wells 7, 8, 9, and 10. These wells are located within the boundaries of the Denair Community Services District.

Source Water Assessment

A Source Water Assessment Plan (SWAP) is now available at our office. This plan is an assessment of the delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area and a determination of the water supply's susceptibility to contamination by the identified potential sources.

According to the SWAP, our water system had a susceptibility rating of medium. If you would like to review the SWAP, please feel free to contact our office during regular office hours at (209) 634-4986.

Important Health Information

Nitrate in drinking water at levels above 10 parts per million (ppm) is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant and detected nitrate levels are above 5 ppm, you should ask advice from your health-care provider.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health-care providers. U.S. Environmental Protection Agency (U.S. EPA)/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or on U.S. EPA's website at epa.gov/safewater.



Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive Contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, the U.S. EPA and the State Water Resources Control Board (SWRCB) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration (FDA) regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

QUESTIONS? For more information about this report, or for any questions relating to your drinking water, please call Denair Community Services District Office at (209) 634-4986.

Service Line Inventory

To address lead in drinking water, public water systems were required to develop and maintain an inventory of service line materials by October 16, 2024.



Developing an inventory and identifying the location of lead service lines (LSL) is the first step for beginning LSL replacement and protecting public health. The lead service inventory may be accessed by submitting a records request on our website, denaircsd.org. Please contact us if you would like more information about the inventory or any lead sampling that has been done.

Community Participation

Our water board meets the third Tuesday of each month (except December) at 6:00 p.m. at the Denair Community Services District office located at 3850 North Graton Road. The public is welcome.

Non-English-Speaking Populations

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Lead in Home Plumbing

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Denair Community Services District is responsible for providing high-quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter certified by an American National Standards Institute-accredited certifier to reduce lead is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure it is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling does not remove lead from water.

Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, or doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead and wish to have your water tested, contact Denair Community Service District at (209) 634-4986. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at epa.gov/safewater/lead.

About Our Violation

The water system was required to collect initial monitoring samples for hexavalent chromium between October 1, 2024, and April 1, 2025. Due to an oversight, the required samples were not collected during this monitoring period. The required initial monitoring samples were collected on June 4, 2025, from all four active wells. All results were below the maximum contaminant level (MCL) of 10 micrograms per liter ($\mu\text{g/L}$). The system has returned to compliance with monitoring requirements. The water system implemented internal procedures to ensure that all future monitoring is completed within the required time frames.

VIOLATION OF A MCL, MRDL, AL, TT OR MONITORING REPORTING REQUIREMENT

VIOLATION	EXPLANATION	DURATION	ACTIONS TAKEN TO CORRECT VIOLATION	HEALTH EFFECTS LANGUAGE
Monitoring Violation	Failure to conduct initial monitoring for hexavalent chromium during October 1, 2024 to April 1, 2025	April 2, 2025 to June 3, 2025	Samples were collected on June 4, 2025	Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.



Test Results

Our water is monitored for many different kinds of substances on a very strict sampling schedule, and the water we deliver must meet specific health standards. Here, we only show those substances that were detected in our water (a complete list of all our analytical results is available upon request). Remember that detecting a substance does not mean the water is unsafe to drink; our goal is to keep all detects below their respective maximum allowed levels.

The state recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data is included, along with the year in which the sample was taken.

We participated in the fifth stage of the U.S. EPA's Unregulated Contaminant Monitoring Rule (UCMR5) program by performing additional tests on our drinking water. UCMR5 sampling benefits the environment and public health by providing the U.S. EPA with data on the occurrence of contaminants suspected to be in drinking water to determine if it needs to introduce new regulatory standards to improve drinking water quality. Unregulated contaminant monitoring data is available to the public, so please feel free to contact us if you are interested in obtaining that information. If you would like more information on the U.S. EPA's Unregulated Contaminant Monitoring Rule, please call the Safe Drinking Water Hotline at (800) 426-4791.



REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Arsenic (ppb)	2025	10	0.004	4.23	NA	No	Erosion of natural deposits; Runoff from orchards; Glass and electronics production wastes
Chromium, Total (ppb)	2025	50	(100)	ND	NA	No	Discharge from steel and pulp mills and chrome plating; Erosion of natural deposits
Dibromochloropropane [DBCP] (ppt)	2025	200	3	100	ND-410	No	Banned nematocide that may still be present in soils due to runoff/leaching from former use on soybeans, cotton, vineyards, tomatoes, and tree fruit
Ethylene Dibromide [EDB] (ppt)	2023	50	10	ND	NA	No	Discharge from petroleum refineries; Underground gas tank leaks; Banned nematocide that may still be present in soils due to runoff and leaching from grain and fruit crops
Fluoride (ppm)	2024	2.0	1	0.19	ND-0.19	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	2024	15	(0)	7.47	NA	No	Erosion of natural deposits
Hexavalent Chromium (ppb)	2025	10	20	3.8175	2.8-4.96	Yes	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; Erosion of natural deposits
Nitrate [as nitrogen] (ppm)	2025	10	10	5.28	3.5-10.9	No	Runoff and leaching from fertilizer use; Leaching from septic tanks and sewage; Erosion of natural deposits
Uranium (NTU)	2024	20	0.43	0.12	0.04-4.48	No	Erosion of natural deposits

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	PHG (MCLG)	AMOUNT DETECTED (90TH %ILE)	RANGE LOW-HIGH	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2024	1.3	0.3	0.119	NA	0/20	No	Internal corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2024	15	0.2	ND	ND-ND	0/20	No	Corrosion of household plumbing systems, Erosion of natural deposits.



SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	PHG (MCLG)	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chloride (ppm)	2023	500	NS	8.1	7.3–8.9	No	Runoff/leaching from natural deposits; Seawater influence
Color (units)	2024	15	NS	ND	NA	No	Naturally occurring organic materials
Manganese (ppb)	2024	50	NS	ND	NA	No	Leaching from natural deposits
Odor, Threshold (TON)	2023	3	NS	ND	NA	No	Naturally occurring organic materials
Specific Conductance (µmho/cm)	2024	1,600	NS	22.1	16.4–27.8	No	Substances that form ions when in water; Seawater influence
Sulfate (ppm)	2023	500	NS	13.8	13.5–14.1	No	Runoff/leaching from natural deposits; Industrial wastes
Total Dissolved Solids (ppm)	2024	1,000	NS	218	198–238	No	Runoff/leaching from natural deposits
Turbidity (NTU)	2024	5	NS	0.12	0.04–0.20	No	Soil runoff

UNREGULATED SUBSTANCES ¹

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Alkalinity (ppm)	2025	56.4	56.40–56.40	Naturally occurring minerals
Boron (ppb)	2021	31	31–31	NA
Calcium (ppm)	2025	23.5	23.3–23.8	Naturally occurring minerals
Hardness, Total [as CaCO ₃] (ppm)	2025	88.3	87.7–88.9	Sum of polyvalent cations present in the water, generally naturally occurring magnesium and calcium
Magnesium (ppm)	2025	7.15	6.9–7.40	Naturally occurring minerals
Molybdenum (ppb)	2021	1.61	1.61–1.61	NA
pH (units)	2024	7.9	7.9–7.9	NA
Sodium (ppm)	2024	22.1	16.4–27.8	Salt present in the water, generally naturally occurring
Strontium (ppb)	2021	253	253–253	NA
Trichloropropane [1,2,3-TCP] (ppb)	2025	ND	NA	NA
Vanadium (ppb)	2021	40.90	40.90–40.90	NA

¹ Unregulated contaminant monitoring helps U.S. EPA and the SWRCB determine where certain contaminants occur and whether the contaminants need to be regulated.

Definitions

90th %ile: The levels reported for lead and copper represent the 90th percentile of the total number of sites tested. The 90th percentile is equal to or greater than 90% of our lead and copper detections.

AL (Regulatory Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NS: No standard.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

pCi/L (picocuries per liter): A measure of radioactivity.

PDWS (Primary Drinking Water Standard): MCLs and MRDLs for contaminants that affect health, along with their monitoring and reporting requirements and water treatment requirements.

PHG (Public Health Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

ppt (parts per trillion): One part substance per trillion parts water (or nanograms per liter).

TON (Threshold Odor Number): A measure of odor in water.

µmho/cm (micromhos per centimeter): A unit expressing the amount of electrical conductivity of a solution.